

# Licensed Electrician's Theory (LET) Assessment Marking Guide Sample Paper 2025

## AS/NZS 3000:2018 Electrical installations – Wiring Rules

### Question 1

No (2 marks)

Clause 4.4.4.2 (2 marks)

### Question 2

Yes (2 marks)

Clause 5.4.6.1 (2 marks)

### Question 3

the highest voltage likely to occur in normal operation (2 marks)

Clause 2.7.3 (b) (2 marks)

### Question 4

Yes (2 marks)

Clause 4.6 (2 marks)

## AS/NZS 3012:2019 Electrical installations – Construction and demolition sites

### Question 5

A qualified person (2 marks)

Clause 3.3.2 (2 marks)

### Question 6

No (2 marks)

Clause 2.6.12 (2 marks)

## Electrical Safety (General) Regulations 2019

### Question 7

Yes (2 marks)

Regulation 249 (1) (c) (2 marks)

## Electrical Shock Survival

### Question 8

Look, listen and feel. (2 marks)

When the patient is unresponsive and not breathing normally. (2 marks)

## Cable Selection

### Question 9

#### Part (i)

Table 3(3) Item 4 (1 mark - item number is optional do not deduct marks)

Table 14 Col 23 (2 marks)

Table 25(2) Col 6 Derating for Distance 3 circuits = 0.9 (1 mark)

Table 28(1) Col 2 Derating for Depth 0.8m = 0.97

3 cables in parallel  $450 / 3 = 150\text{A}$  per cable

$35\text{mm}^2 = 172\text{A}$

$172 \times 0.9 \times 0.97 = 150.16\text{A}$

Answer  $35\text{mm}^2$

#### Part (ii)

Table 25(2) Col 3 Derating for spacing of 0.15 m = 0.78

$50\text{mm}^2 = 204\text{A}$

$204 \times 0.78 \times 0.97 = 154.35\text{A}$

Answer =  $50\text{mm}^2$  (1 mark for all)

Deduct 1 mark for no or incorrect units.

## Ohms Law

### Question 10

Meter X = 160W (2 marks)

Meter Y = 0.67A (2 marks)

Meter Z =  $60.15\Omega$  (2 marks)

Deduct 1 mark for no or incorrect units.

## Maximum Demand

### Question 11

Table C2 Column 3 (1 mark)

- 1 - 4.5kW Instantaneous hot water service
- 1 - 4kW Oven
- 40 - 10W LED lighting points
- 2 - 15A socket outlets
- 5 - 10A double socket outlets

### School

Table C2 Column 3

Equipment	Load Group	Calculation	Maximum Demand
1 – 4.5kW Instantaneous hot water service	(c)(i)	Full connected load 21.74A $4500/230 = 19.56A$	19.57A (1 mark)
1 – 4kW Oven	(c)(i)	75% connected load $4000/230 \times 75\% = 13.04A$	13.04A (1 mark)
40 – 10W LED lighting points	(a)	Full connected load $400/230 = 1.74A$	1.74A (1 mark)
2 – 15A socket outlets	(b)(iii)	Full current rating of highest rated 75% of FLC of remainder $15 + (15 \times 0.75) = 26.25A$	26.25A (2 mark)
5 – 10A double socket outlets 10 Points total	(b)(i)	$1000W + (750 \times 9) = 7750$ $7750/230 = 33.70A$	33.70A (1 mark)
<b>Total Maximum Demand</b>			94.30A (1 mark)

Deduct 1 mark for no or incorrect units on total. Deduct 1 mark for no or incorrect load groups.

## Voltage Drop

### Question 12

#### Consumer's Mains

Table 41 Column 10 (1 mark)

Vc 1.25 (1 mark)

Vd =  $130 \times 11 \times 1.25/1000$

Vd 1.79V (1 mark)

#### Sub-mains

Table 45 Column 6 (1 mark)

Vc 2.54 (1 mark)

$$V_d = 50 \times 55 \times 2.54/1000$$

V<sub>d</sub> 6.99V (1 mark)

### Final Sub-circuit

Table 42 Column 6 (1 mark)

V<sub>c</sub> 15.6 (1 mark)

$$V_d = 19 \times 35 \times 15.6/1000$$

V<sub>d</sub> 10.37V (1 mark)

Total Voltage Drop = 1.79 + 6.99 + 10.37 = 19.15 V (1 mark)

Deduct 1 mark for no or incorrect units on total. Deduct 1 mark for no or incorrect table number/s.

## Overload and Short Circuit Calculations

### Question 13

Overcurrent divided by MCB current rating = 4 (1 mark)

Minimum Time = Accept 2 – 2.2 seconds (1 mark)

Maximum Time = Accept 7 - 9 seconds (1 mark)

Deduct 1 mark for no or incorrect time unit.

### Question 14

#### Transformer impedance

230/22000 (2 marks)

0.01045Ω (1 mark) Answer must be to **5 decimal places**.

#### Main switchboard prospective fault

230/ (0.01045 +0.0019) (2 marks)

18,623A (1 mark)

#### Distribution board prospective fault

230/ (0.01045 +0.0019+ 0.0087) (2 marks)

10,926A (1 mark)

Deduct 1 mark for no or incorrect units in final answer.

## Residual Current Devices

### Question 15

24A (2 marks)

## Motor and Starters

### Question 16

B (2 marks)

## AS/NZS 4836:2023 Safe working on or near low-voltage and extra-low voltage electrical installations and equipment

### Question 17

Before and after each use. (2 marks)

Clause number: 8.5.2 (2 marks)

## Installation Defects – Non-Domestic

### Question 18

2 marks for correct defect, 1 mark for the correct clause.

Only some of the defects have been listed below, there are more than 10 defects in the diagram. All correct defects and clauses will be awarded marks.

Only accept the first 5 defects a candidate has listed.

1. Consumer's mains not installed in a manner that can maintain supply if exposed to fire - 7.2.2.1
2. No short circuit protection has been provided at the origin of the consumer's mains - 2.5.1.2 (b)
3. Main Earthing conductor is not provided with insulation - 5.3.2.4
4. The telecommunications earthing conductor is undersized, - 5.6.2.7 (iv)
5. Overcurrent protective device is not rated to carry 125% of the full load current of the fire pump - 7.2.5.6.2 (b) (i)
6. Distribution isolator not marked 'ON' or 'OFF' 2.3.2.2.1 (c )
7. The cable to the distribution board is undersized - 3.4.1
8. Main switch distribution board not labelled 'Main Switch' - 2.3.3.5(a)
9. Main switch fire pump not labelled 'IN THE EVENT OF FIRE DO NOT SWITCH OFF' - 7.2.4.4(b)
10. Strip earth electrode not at minimum horizontal length - 5.3.6.3(i)